



**TITLE:**

OSP Overall Foil Screened Pairs LSZH

**CODE:**

SFX/OSP1-61-LSZH-GRY-1


**DESCRIPTION:**

1m (per metre) OSP1-61 1pr 22AWG  
Overall Foil Screen 600V Grey LSZH  
(8761)

**SUPPLIED AS:**

Per 1m Lengths

- Additional screening makes this cable suitable to be installed in areas where protection from electrical interference is required
- A general purpose small diameter cable
- Low smoke zero halogen plastic is good for use inside public buildings and spaces as will not emit toxic gases if the cable catches fire
- Improved performance and protection against fire





# Product Specification



25-YEAR WARRANTY

## Cable Construction

Cable Construction	1 Pair
CPR	Eca
Conductor	Tinned Copper
Conductor Diameter (mm)	7 x 0.30
Stranded Diameter (mm)	0.36
Overall Diameter (mm)	4.40 ±0.20

## Insulation

Insulation	HDPE
Insulation Colour	Black, Clear
Insulation Resistance @20°C	>200MO/km
Insulation Thickness (mm)	0.43

## Outer/Jacket Specification

Jacket	LSZH
Overall Colour	Grey
Overall Diameter (mm)	4.40 ±0.20
Jacket Colour	Grey RAL 7042
Jacket Thickness (mm)	0.6

## Electrical Characteristics

Insulation Resistance @20°C	>200MO/km
Max Conductor DC resistance @ 20°C	<56.000/km
Rated Temperature (°C)	-40°C to 70°C
Rated Voltage (V)	600V



[enquiries@securiflex.co.uk](mailto:enquiries@securiflex.co.uk) | [www.securiflex.co.uk](http://www.securiflex.co.uk) | 03333 44 66 23

## **MORE INFORMATION:**

CLASSIFICATION CRITERIA		CPR GUIDE		
EURO CLASS (ca:cable)	FIRE RATING 	SFX COMMENT	SUBCLASSIFICATIONS FOR EUROCLASSES Bca to Dca	
Reaction to Fire BS EN ISO 1716				
<b>A<sub>ca</sub></b>	Does not contribute to the fire	Due to availability, it will be almost impossible for a cable to meet Aca, so they should only be specified with extreme caution.	(S) SMOKE PRODUCTION 	(D) FLAMING DROPLETS 
Reaction to Fire BS EN 50399				BS EN 60754-2
<b>B1<sub>ca</sub></b>	Minimum contribution to the fire	It's highly unlikely the commonly-used cables will be classified to Class B1ca.	s1a: s1 + transmittance >=80% (BS EN 61034-2)	BS EN 50399
<b>B2<sub>ca</sub></b>	Combustible, low flame spread & heat release contribution to the fire	Similar to Class Cca, although a lower acceptable heat release rate and burn measurement. In practice, this is likely to be the highest class cables will meet.	s1b: s1 + transmittance >=60% <80% (BS EN 61034-2)	BS EN 60754-2
<b>C<sub>ca</sub></b>	Combustible, moderate flame spread & heat release	This is a more rigorous test than Class Dca, this is widely accepted across Europe as the 'go to' classification, but be aware, many cables do not meet Class Cca though availability is improving.	s1: Low production of slow propagation of smoke	a1: Very low acidity (conductivity <2.5 $\mu$ S/mm & pH >4.3)
<b>D<sub>ca</sub></b>	Combustible, moderate flame spread & heat release	This classification has relatively little use or acceptance within specifying/contracting organisations. This is because no large scale fire growth is measured.	s2: Intermediate production & propagation of smoke	a2: low acidity (conductivity <10 $\mu$ S/mm & pH >4.3)
Reaction to Fire BS EN 60332-1-2				d1: Fall of droplets or flaming particles that persist for less than 10 seconds, timed for 1200 seconds
<b>E<sub>ca</sub></b>	Combustible, limited fire spread of less than 425mm	A basic test for vertical flame propagation for a single insulated wire or cable using a 1 KW pre-mixed flame. Note: This test does not measure heat release, toxic fumes or smoke.	s3: None of the above	d2: None of the above
<b>F<sub>ca</sub></b>	Combustible, fire spread of more than 425mm	Cables classified to Class Fca may have high levels of flammability due to the materials they are made of. This does not mean that the cable cannot be used, it is more likely to be used external.		
Reaction to Fire BS EN 60332-2-13				Visit us online: <a href="http://www.securiflex.co.uk">www.securiflex.co.uk</a>
Reaction to Fire BS EN 60332-2-14				 The Trusted Cable Brand
Reaction to Fire BS EN 60332-2-15				Classes A to E have to be tested by an independent authorised laboratory. Most cables will fall into classes B2ca to Eca. For a cable to meet Aca, B1ca, B2ca or Cca, there also needs to be regular on-going factory audits.

## OUR OPERATING TEMPERATURE RANGE GUIDE

